Chromium MACT - Work Practice Standards

(Conduct the Work Practice Standards that apply to your operation)

I. Inspection and Maintenance - Pollution Control Techniques

Work Practice Standard	Frequency	Date of inspection (and your initials)	Condition (Good, Fair, Poor)
Visually inspect device to ensure there is proper drainage, no chromic acid build up on the pads, and no evidence of chemical attack on the structural integrity of the device.	Quarterly		
Visually inspect back portion of the mesh pad closest to the fan to ensure there is no breakthrough of chromic acid mist.	Quarterly		
there are no leaks.	Quarterly		
Perform washdown of the composite mesh pads in accordance with manufacturers recommendations	Per manufacturer		
Visually inspect device to ensure there is proper drainage, no chromic acid build up on the packed beds, and no evidence of chemical attack on the structural integrity of the device.	Quarterly		
Visually inspect back portion of the chevron blade mist eliminator to ensure that it is dry and there is no breakthrough of chromic acid mist.	Quarterly		
Visually inspect ductwork from tank or tanks to the control device to ensure there are no leaks.	Quarterly		
Add fresh makeup water to the top of the packed bed.	Whenever makeup is added		
Same as composite mesh-pad system			
Visually inspect fiber-bed unit and pre-filtering device to ensure there is proper drainage, no chromic acid build up in the units, and no evidence of chemical attack on the structural integrity of the devices.	Quarterly		
Visually inspect ductwork from tank or tanks to the control device to ensure there are no leaks.	Quarterly		
Perform washdown of the fiber elements in accordance with manufacturers recommendations	Per manufacturer		
To be proposed by the business for approval.			
	Visually inspect device to ensure there is proper drainage, no chromic acid build up on the pads, and no evidence of chemical attack on the structural integrity of the device. Visually inspect back portion of the mesh pad closest to the fan to ensure there is no breakthrough of chromic acid mist. Visually inspect ductwork from tank or tanks to the control device to ensure there are no leaks. Perform washdown of the composite mesh pads in accordance with manufacturers recommendations Visually inspect device to ensure there is proper drainage, no chromic acid build up on the packed beds, and no evidence of chemical attack on the structural integrity of the device. Visually inspect back portion of the chevron blade mist eliminator to ensure that it is dry and there is no breakthrough of chromic acid mist. Visually inspect ductwork from tank or tanks to the control device to ensure there are no leaks. Add fresh makeup water to the top of the packed bed. Same as composite mesh-pad system Visually inspect fiber-bed unit and pre-filtering device to ensure there is proper drainage, no chromic acid build up in the units, and no evidence of chemical attack on the structural integrity of the devices. Visually inspect ductwork from tank or tanks to the control device to ensure there are no leaks. Perform washdown of the fiber elements in accordance with manufacturers recommendations	Visually inspect device to ensure there is proper drainage, no chromic acid build up on the pads, and no evidence of chemical attack on the structural integrity of the device. Visually inspect back portion of the mesh pad closest to the fan to ensure there is no breakthrough of chromic acid mist. Visually inspect ductwork from tank or tanks to the control device to ensure there are no leaks. Perform washdown of the composite mesh pads in accordance with manufacturer manufacturers recommendations Visually inspect device to ensure there is proper drainage, no chromic acid build up on the packed beds, and no evidence of chemical attack on the structural integrity of the device. Visually inspect back portion of the chevron blade mist eliminator to ensure that it is dry and there is no breakthrough of chromic acid mist. Visually inspect ductwork from tank or tanks to the control device to ensure there are no leaks. Add fresh makeup water to the top of the packed bed. Visually inspect fiber-bed unit and pre-filtering device to ensure there is proper drainage, no chromic acid build up in the units, and no evidence of chemical attack on the structural integrity of the devices. Visually inspect ductwork from tank or tanks to the control device to ensure there is proper drainage, no chromic acid build up in the units, and no evidence of chemical attack on the structural integrity of the devices. Visually inspect ductwork from tank or tanks to the control device to ensure there is proper drainage, no chromic acid build up in the units, and no evidence of chemical attack on the structural integrity of the devices. Visually inspect ductwork from tank or tanks to the control device to ensure there are no leaks.	Visually inspect device to ensure there is proper drainage, no chromic acid build up on the pads, and no evidence of chemical attack on the structural integrity of the device. Visually inspect back portion of the mesh pad closest to the fan to ensure there is no breakthrough of chromic acid mist. Visually inspect ductwork from tank or tanks to the control device to ensure there are no leaks. Perform washdown of the composite mesh pads in accordance with manufacturers recommendations Visually inspect device to ensure there is proper drainage, no chromic acid build up on the packed beds, and no evidence of chemical attack on the structural integrity of the device. Visually inspect back portion of the chevron blade mist eliminator to ensure that it is dry and there is no breakthrough of chromic acid mist. Visually inspect ductwork from tank or tanks to the control device to ensure there are no leaks. Add fresh makeup water to the top of the packed bed. Visually inspect fiber-bed unit and pre-filtering device to ensure there is proper drainage, no chromic acid build up in the units, and no evidence of chemical attack on the structural integrity of the devices. Visually inspect fiber-bed unit and pre-filtering device to ensure there is proper drainage, no chromic acid build up in the units, and no evidence of chemical attack on the structural integrity of the devices. Visually inspect ductwork from tank or tanks to the control device to ensure there are no leaks. Perform washdown of the fiber elements in accordance with manufacturers recommendations

II. Inspection and Maintenance - Monitoring Equipment

Equipment	Work Practice Standard	Frequency	Date of inspection (and your initials)	Date of Maintenance (and your initials)
Pitot tube Tank(s) ID#	Backflush with water, or remove from the duct and rinse with fresh water. Replace in the duct and rotate 180 degrees to ensure that the same zero reading is obtained. Check pitot tube ends for damage. Replace pitot tube if cracked or fatigued.	Quarterly		
Stalagmometer Tanks ID#	Follow manufacturers recommendations.			

III. Maintenance Performed

Describe actions taken and maintenance performed to process, air	pollution control device,	and/or monitoring equipment.	(Otherwise retain dated, hand	dwritten
descriptions and/or a contractor's invoice that describes the work.)				

1.	Tank #:	_ Date://	Initials:	Supervisor informed (Y/N):
2.	Tank #:	_ Date://	Initials:	_ Supervisor informed (Y/N):
3.	Tank # <u>:</u>	_ Date:/_/_	Initials:	_ Supervisor informed (Y/N):

IV. Malfunction Records

Describe malfunction (include Tank(s) # and process, air pollution control device, and/or monitoring equipment):							
Duration of malfunction:// thru//							
Explain cause of malfunction:							
Was the action taken to correct the malfunction the same as what is describe in your O&M plan? Yes or No							
f the action was different, did you revise your O&M plan accordingly? Please explain.							